

## Florida Division of State Fire Marshal

The Florida Fire Marshals and Inspectors Association, "Organization" (§633.026)

## **Informal Interpretation**

Date: 9/28/19

NFPA Document Number: NFPA 1 Edition: 2015 Florida Specific

## Paragraph Reference: NFPA 1 13.3.2.27.4

Explain how the Petitioner's substantial interests are being affected by the LFO's interpretation of the NFPA citation above: <u>Have a self storage project in plan review for building permit. Buildings in question</u> are single story drive up self storage subdivided into 2500 sf buildings with 3 hour firewalls, individual units defined by non-rated metal partitions. Section above would also require demising walls be one (1) hour fire barriers to avoid fire sprinklers.

Enter a statement of the LFO's interpretation of the NFPA citation above and identify the manner in which the statement was rendered: <u>LFO indicates 2500 SF max building and one hour separation around</u> individual units. Interpretation offered as plan review comment.

Enter a statement of the interpretation that the Petitioner contends should be given to the NFPA citation above and a statement supporting the Petitioner's interpretation: <u>Citation should require max 2500 SF bldg</u> where individual units are not one hour fire separated, as is stated in 5th Edition. 6th Edition does not flag change from 5th edition as a revision and in my opinion 6th edition says same thing, but not as clearly.

Explain how the Petitioner's substantial interests are being affected by the question below:

Enter the Petitioner's question concerning an interpretation of the FFPC:

Florida Fire Marshals and Inspectors Association | P. O. Box 325 Hobe Sound, FL 33475 | Tel 772-349-1507 | Fax 772-546-6675



## <u>Florida Division of State Fire</u> <u>Marshal</u>

The Florida Fire Marshals and Inspectors Association, "Organization" (§633.026)

Answer: No (Question Inferred by the Committee)

There is not really a question being asked here but the majority of the committee believes as follows:

Is an automatic fire sprinkler system required in a mini-storage building that is less than 2,500 square feet with individual units that are not separated by at least a 1-hourfire resistance-rated barrier?

No. The language in 13.3.2.27.4 established two criteria: 1. Building greater than 2,500 square feet and 2. Units separated by less than a 1-hour fire-resistance rated barrier. The inclusion of "and" in the code text means that both criteria would have to be met in order to require fire sprinklers

Examples:

- A. Building is 5,000 square feet an1 hr rated fire partitions: No fire sprinklers required
- B. Building is 2,000 square feet and has no fire rated partitions separating the units: No fire sprinklers required.
- C. Building is 5,000 square feet and no fire rated partitions separating the units: Fire sprinklers required.

Committee Answer Submitted by, Jon Pasqualone, FFMIA Executive Director Acting on behalf of Chair of the Informal Fire Code Interpretation Committee

Region 1: Vacant / Vacant Region 2: Babette Ferris-No response / Vacant Region 3: James Groff-N/A Recused Robert Growick-No response Region 4: Philip Guglietti-No / Cheryl Edwards-Yes Region 5: Anthony Apfelbeck –No/ Timothy Ippolito- No response Region 6: Robert Salvaggio-No /Alternate Kathy Szostak- No Region 7: Bryan Parks-No Response

Rulings herein expressed are not the formal position of the Florida State Fire Marshal's Office

Florida Fire Marshals and Inspectors Association | P. O. Box 325 Hobe Sound, FL 33475 | Tel 772-349-1507 | Fax 772-546-6675