

## Florida Division of State Fire Marshal

The Florida Fire Marshals and Inspectors Association, In accordance with FAC 69A-60.011

#### **Informal Interpretation**

**Date:** 6/25/19

NFPA Document Number: NFPA 1 2015 Edition

Paragraph Reference: 10.11.6.3

10.10.6.3\* Listed equipment permanently installed in accordance with its listing, applicable codes, and manufacturer's instructions shall be permitted.

For purpose of this petition, pertinent factors do not include the name of the governmental agency or persons representing that agency. Petitioners are discouraged from making any personal assertions about an agency or agency official. If this involves an actual situation, briefly explain all of the pertinent factors.

Explain how the Petitioner's substantial interests are being affected by the LFO's interpretation of the NFPA citation above: Enter a statement of the LFO's interpretation of the NFPA citation above and identify the manner in which the statement was rendered:

LFO has interpreted 10.11.6.3 to require any listed equipment (grills) to be only allowed to be installed in locations greater than 10 feet from the structure and in locations without overhangs.

Explain how the Petitioner's substantial interests are being affected by the LFO's interpretation of the NFPA citation above:

The LFO's initial interpretation is preventing us from fulfilling a request by our client to provide grills on the balconies of a Condominium project.

#### **Question:**

If the requirements of NFPA 1 10.11.6.3 are met (grill is installed in accordance with its listing, applicable codes, and manufacturer's instructions) does the requirement of NFPA 1 10.10.6.1 prohibition of cooking equipment on any balcony or within 10 feet of any structure still apply?

Answer: No

It is the Boards opinion that NFPA 1 10.11.6.3 does allow permanently installed grills to be installed in accordance with their listing, following all applicable codes and manufacturer's instructions without also applying NFPA 1 10.10.6.1.

Note: Most if not all listing require minimum clearances from combustibles from back and sides and cooking gas appliances to not be located under overhead-unprotected combustible construction.

Rulings herein expressed are not the formal position of the Florida State Fire Marshal's Office

Florida Fire Marshals and Inspectors Association | P. O. Box 325 Hobe Sound, FL 33475 | Tel 772-349-1507 | Fax 772-546-6675



### Florida Division of State Fire Marshal

The Florida Fire Marshals and Inspectors Association, In accordance with FAC 69A-60.011

Fire Code Interpretation Committee Answer Submitted by, James Groff, Chairman

Region 1: Vacant

Region 2: Babette Ferris (NR)

Region 3: James Groff (No) Robert Growick

Region 4: Philip Gugliettie (NR) Cheryl Edwards (No)

Region 5: Anthony Apfelbeck (No) Tim Ippolito (No) Region 6: Robert Salvaggio (No) Kathy Szostak (No)

Region 7: Bryan Park (No) Janet Washburn (NR)

Region 1 - Delegate: Vacant Alternate: N/A\*

Region 2 - Delegate: Babette Ferris, Tallahassee Fire Department

Alternate: N/A\*

Region 3 - Delegate: James Groff, Jacksonville F. R. (Committee Chair)

Alternate: Robert Growick

Region 4 - Delegate: Philip Gugliettie, St. Petersburg F.R.

Alternate: Cheryl Edwards

Region 5 - Delegate: Anthony Apfelbeck, Altamonte Springs Building Department

Alternate: Tim Ippolito, Casselberry F. R.

Region 6 - Delegate: Robert Salvaggio

Alternate: Kathy Szostak, City of Naples

Region 7 - Delegate: C. Bryan Park, Broward County Board of Rules & Appeals

Alternate: Janet Washburn, City of Hollywood Fire Rescue



# Florida Division of State Fire Marshal

The Florida Fire Marshals and Inspectors Association, In accordance with FAC 69A-60.011

#### **Committee Region Map**

